

NAPA SANITATION DISTRICT MEMORANDUM

DATE: December 10, 2024
TO: LCWD Board of Directors
FROM: Andrew Damron, NapaSan
SUBJECT: Recycled Water Update

Purpose

Update the LCWD Board on the status of the recycled water connections, usage, and recycled water quality data.

<u>Description</u>	<u>2016</u>	2017	<u>2018</u>	2019	2020	<u>2021</u>	2022	2023	2024
Summer Water Use (AF) (May	110	194	239	210	436	819	591	371	446
- Oct) - Allocation = 450 AF									
Calendar Year Actual Water	122	197	319	274	636	1,147	824	383	456*
Use (AF)									
Connected Parcels (out of 107)									74 (69%)
Connected Acres (out of 4,128)									2,971 (72%)
Peak Hour Flow (GPM) **			2,400	2,425	3,260	3,211	4,150	2,700	3,900
Peak Day Flow (GPM) **			1,950	2,200	2,680	2,760	2,400	1,900	2,600

^{*}Data through October 31, 2024

Water Quality Data

The last Chloride sample was taken on 10/01/24 – Chloride Reading (mg/L)	205
--	-----


NapaSan Contacts

For questions related to permitting including plan review, inspection, pressure and flow	Matt Lemmon Gavin Glascott	707-258-6004 707-258-6012	mlemmon@napasan.com gglascott@napasan.com	
For questions on recycled water service and pressure issues	Kyle Tahsler	707-312-1609	ktahsler@napsan.com	
For a construction related question or to schedule an inspection	Josh DeGarmo Brad Cagle	707-312-1613 707-312-1761	bcagle@napasan.com	
For questions related to recycled water quality	Chris Francis	707-258-6081	cfrancis@napasan.com	
For questions on billing	Donell Mannor	707-258-6032	dmannor@napasan.com	

^{**} Approximately 3,500 GPM design capacity (peak day in 2024 was 7/16; peak hour 8am on 7/17)

Chloride Chart

Go to www.napasan.com for updates.



LCWD Connected Parcels as of December 10, 2024

